



Town of THREE HILLS

ADDENDUM #1

Date: May 21, 2026

Project: Replacement of Brine Pumps and Filters

RFQ Closing Date: June 5, 2026, at 4:00 PM Local Time

Additional Pictures of Pumps





Town of THREE HILLS





Town of THREE HILLS

Error in RFQ: Please note that although the RFQ references close-coupled pumps, we intend to remain with open-driven pumps to match the existing system configuration.

The brine filter housing are being replaced due to age and inability to purchase replacement parts.